

Table 6. HTP BIOSOLIDS - CLASS A COMPLIANCE MONITORING DATA

Sampling Date	%TS	FECAL COLIFORM		SALMONELLA, sp.		HELMINTH OVA			ENTERIC VIRUS		
		MPN/gram TS (dry wt)		MPN/4 grams TS (dry wt)		Viable Helminth Ova/4 grams TS (dry wt)			PFU/4 grams TS (dry wt)		
		Silo#/Farm		Silo#/Farm		Raw Sludge	Silo#/Farm		Raw Sludge	Silo#/Farm	
December 9, 2014	27.1	Silo #2	16.6	Silo #2	<1.5	5.5	Silo #2	<0.5	8.2	Silo #2	<0.5
November 4, 2014	25.9	Silo #2	<6.9	Silo #2	<1.6	6.0	Silo #2	<0.5	15.2	Silo #2	<0.5
October 7, 2014	26.4	Farm	<6.8	Farm	<1.6	9.4	Farm	<0.5	13.2	Farm	<0.5
September 9, 2014	26.6	Silo #2	<6.8	Silo #2	<1.3	7.5	Silo #2	<0.5	5.4	Silo #2	<0.5
August 5, 2014	26.7	Silo #2	<6.7	Silo #2	<1.6	11.7	Silo #2	<0.5	28.9	Silo #2	<0.5
July 8, 2014	25.6	Farm	<7.8	Farm	<1.7	4.4	Farm	<0.5	24.8	Farm	<0.5
June 3, 2014	25.4	Silo	<7.9	Silo	<1.7	4.7	Silo	<0.5	14.7	Silo	<0.5
May 6, 2014	27.8	Silo #5	<7.2	Silo #5	<1.5	6.4	Silo #5	<0.5	14.8	Silo #5	<0.5
April 8, 2014	27.8	Farm	<7.2	Farm	<1.5	6.9	Farm	<0.5	21.6	Farm	<0.5
March 4, 2014	28.3	Silo #5	<7.1	Silo #5	<1.4	6.8	Silo #5	<0.4	20.3	Silo #5	<0.5
February 4, 2014	27.8	Silo #5	14.4	Silo #5	<1.5	8.9	Silo #5	<0.5	32.9	Silo #5	<0.4
January 13, 2014	25.3	Farm	<7.9	Farm	<1.5	5.2	Farm	<0.5	23.5	Farm	<0.5
Requirement**			<1000		<3			<1			<1

\* - EPA 40 CFR Part 503 Class A requirements  
 NA - Data not yet available from Biovir.  
 NS - No Sampling Required

**Table 7. TIWRP BIOSOLIDS - CLASS A COMPLIANCE MONITORING DATA**

Sampling Date	TOTAL SOLIDS		FECAL COLIFORM		SALMONELLA, sp.	
	%		MPN/gram TS (dry wt)		MPN/4 grams TS (dry wt)	
	Silo#/Farm		Silo#/Farm		Silo#/Farm	
	6 Times/Year@		6 Times/Year@		Quarterly	
Dec-14	NS	NS	NS	NS	NS	NS
Nov-14	TIWRP Digester Sludge	1.83	TIWRP Digester Sludge	<9.8	TIWRP Digester Sludge	<1.6
Oct-14	NS	NS	NS	NS	NS	NS
Sep-14	TIWRP Digester Sludge	1.61	TIWRP Digester Sludge	<11.2	TIWRP Digester Sludge	<2.0
Aug-14	NS	NS	NS	NS	NS	NS
Jul-14	TIWRP Digester Sludge	1.49	TIWRP Digester Sludge	13.4	TIWRP Digester Sludge	<2.1
Jun-14	NS	NS	NS	NS	NS	NS
May-14	TIWRP Digester Sludge	1.67	TIWRP Digester Sludge	<12.0	TIWRP Digester Sludge	<1.6
Apr-14	NS	NS	NS	NS	NS	NS
Mar-14	TIWRP Digester Sludge	1.42	TIWRP Digester Sludge	<14.1	TIWRP Digester Sludge	<2.3
Feb-14	NS	NS	NS	NS	NS	NS
Jan-14	TIWRP Digester Sludge	1.42	TIWRP Digester Sludge	<14.1	TIWRP Digester Sludge	<1.8
Requirement*				<1000		<3

\* - EPA 40 CFR Part 503 Class A requirements

NS - No Sampling Required

@ - Sampling frequency for TIWRP is 6 months/year. The sampling months are: Jan, Mar, May, Jul, Sep and Nov.